

# Handheld Thermography Camera HIKMICRO SP Series

**User Manual** 



Contact Us

# **Legal Information**

Read all information and instructions in this document carefully before using the device and keep it for further reference.

For more device information and instructions, please visit our website at

http://www.hikmicrotech.com. You can also refer to other documents (if any) accompanying the device to get more information.

#### **About this Manual**

The Manual includes instructions for using and managing the Product. Pictures, charts, images and all other information hereinafter are for description and explanation only. The information contained in the Manual is subject to change, without notice, due to firmware updates or other reasons. Please find the latest version of this Manual at the HIKMICRO website (http://www.hikmicrotech.com).

Please use this Manual with the guidance and assistance of professionals trained in supporting the Product.

©2023 Hangzhou Microimage Software Co., Ltd. All rights reserved.

#### **Trademarks**



Other trademarks and logos mentioned are the properties of their respective owners.



The terms HDMI and HDMI High-Definition Multimedia Interface, and the

HDMI Logo are trademarks or registered trademarks of HDMI Licensing Administrator, Inc. in the United States and other countries.

#### Disclaimer

TO THE MAXIMUM EXTENT PERMITTED BY APPLICABLE LAW, THIS MANUAL AND THE PRODUCT DESCRIBED, WITH ITS HARDWARE, SOFTWARE AND FIRMWARE, ARE PROVIDED "AS IS" AND "WITH ALL FAULTS AND ERRORS". HIKMICRO MAKES NO WARRANTIES, EXPRESS OR IMPLIED, INCLUDING WITHOUT LIMITATION, MERCHANTABILITY, SATISFACTORY QUALITY, OR FITNESS FOR A PARTICULAR PURPOSE. THE USE OF THE PRODUCT BY YOU IS AT YOUR OWN RISK. IN NO EVENT WILL HIKMICRO BE LIABLE TO YOU FOR ANY SPECIAL, CONSEQUENTIAL, INCIDENTAL, OR INDIRECT DAMAGES, INCLUDING, AMONG OTHERS, DAMAGES FOR LOSS OF BUSINESS PROFITS, BUSINESS INTERRUPTION, OR LOSS OF DATA, CORRUPTION OF SYSTEMS, OR LOSS OF DOCUMENTATION, WHETHER BASED ON BREACH OF CONTRACT, TORT (INCLUDING NEGLIGENCE), PRODUCT LIABILITY, OR OTHERWISE, IN CONNECTION WITH THE USE OF THE PRODUCT, EVEN IF HIKMICRO HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES OR LOSS.

YOU ACKNOWLEDGE THAT THE NATURE OF THE INTERNET PROVIDES FOR INHERENT SECURITY

#### Handheld Thermography Camera User Manual

RISKS, AND HIKMICRO SHALL NOT TAKE ANY RESPONSIBILITIES FOR ABNORMAL OPERATION, PRIVACY LEAKAGE OR OTHER DAMAGES RESULTING FROM CYBER-ATTACK, HACKER ATTACK, VIRUS INFECTION, OR OTHER INTERNET SECURITY RISKS; HOWEVER, HIKMICRO WILL PROVIDE TIMELY TECHNICAL SUPPORT IF REQUIRED.

YOU AGREE TO USE THIS PRODUCT IN COMPLIANCE WITH ALL APPLICABLE LAWS, AND YOU ARE SOLELY RESPONSIBLE FOR ENSURING THAT YOUR USE CONFORMS TO THE APPLICABLE LAW. ESPECIALLY, YOU ARE RESPONSIBLE, FOR USING THIS PRODUCT IN A MANNER THAT DOES NOT INFRINGE ON THE RIGHTS OF THIRD PARTIES, INCLUDING WITHOUT LIMITATION, RIGHTS OF PUBLICITY, INTELLECTUAL PROPERTY RIGHTS, OR DATA PROTECTION AND OTHER PRIVACY RIGHTS. YOU SHALL NOT USE THIS PRODUCT FOR ANY PROHIBITED END-USES, INCLUDING THE DEVELOPMENT OR PRODUCTION OF WEAPONS OF MASS DESTRUCTION, THE DEVELOPMENT OR PRODUCTION OF CHEMICAL OR BIOLOGICAL WEAPONS, ANY ACTIVITIES IN THE CONTEXT RELATED TO ANY NUCLEAR EXPLOSIVE OR UNSAFE NUCLEAR FUEL-CYCLE, OR IN SUPPORT OF HUMAN RIGHTS ABUSES.

IN THE EVENT OF ANY CONFLICTS BETWEEN THIS MANUAL AND THE APPLICABLE LAW, THE LATER PREVAILS.

# **Regulatory Information**

These clauses apply only to the products bearing the corresponding mark or information.

#### **FCC Information**

Note: This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense. Please take attention that changes or modification not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment. This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions:

- (1) this device may not cause harmful interference, and
- (2) this device must accept any interference received, including interference that may cause undesired operation.

Note: Due to the device size limit, the above statement may not be disclaimed on the device.

### **EU Conformity Statement**



This product and - if applicable - the supplied accessories too are marked with "CE" and comply therefore with the applicable harmonized European standards listed under the Directive 2014/30/EU (EMCD), Directive 2014/35/EU (LVD), Directive 2011/65/EU (RoHS).



This product and - if applicable - the supplied accessories too are marked with "UKCA" and comply therefore with the following directives: Radio Equipment Regulations 2017, Electromagnetic Compatibility Regulations 2016, Electrical Equipment (Safety) Regulations 2016, the Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012.

#### Restrictions in the 5 GHz band:

According to Article 10 (10) of Directive 2014/53/EU, when operating in the 5150 to 5350 MHz frequency range, this device is restricted to indoor use in: Austria (AT), Belgium (BE), Bulgaria (BG), Croatia (HR), Cyprus (CY), the Czech Republic (CZ), Denmark (DK), Estonia (EE), Finland (FI), France (FR), Germany (DE), Greece (EL), Hungary (HU), Iceland (IS), Ireland (IE), Italy (IT), Latvia (LV), Liechtenstein (LI), Lithuania (LT), Luxembourg (LU), Malta (MT), Netherlands (NL), Northern Ireland

(UK(NI)), Norway (NO), Poland (PL), Portugal (PT), Romania (RO), Slovakia (SK), Slovenia (SI), Spain (ES), Sweden (SE), Switzerland (CH), and Turkey (TR).

In accordance with the Radio Equipment Regulations 2017 in the UK, the device working in the 5150 to 5350 MHz frequency range is restricted to indoor use in the United Kingdom.

#### Frequency Bands and Power (for CE/UKCA)

The frequency bands and modes and transmitting power (radiated and/or conducted) nominal limits applicable to the following radio equipment are as follows:

**Wi-Fi:** 2.4 GHz (2.4 GHz to 2.4835 GHz): 20 dBm; 5 GHz (5.15 GHz to 5.25 GHz): 23 dBm; 5 GHz (5.25 GHz to 5.35 GHz): 23 dBm; 5 GHz (5.725 GHz to 5.85 GHz): 14 dBm

Bluetooth: 24 GHz (2.4 GHz to 2.4835 GHz): 20 dBm

Use the power adapter provided by a qualified manufacturer. Refer to the product specification for detailed power requirements.

Use the battery provided by a qualified manufacturer. Refer to the product specification for detailed battery requirements.



Directive 2012/19/EU (WEEE Directive): Products marked with this symbol cannot be disposed of as unsorted municipal waste in the European Union. For proper recycling, return this product to your local supplier upon the purchase of equivalent new equipment, or dispose of it at designated collection points. For more information see: www.recyclethis.info

According to the Waste Electrical and Electronic Equipment Regulations 2013: Products marked with this symbol cannot be disposed of as unsorted municipal waste in the United Kingdom. For proper recycling, return this product to your local supplier upon the purchase of equivalent new equipment, or dispose of it at designated collection points. For more information see: www.recyclethis.info.



Directive 2006/66/EC and its amendment 2013/56/EU (Battery Directive): This product contains a battery that cannot be disposed of as unsorted municipal waste in the European Union. See the product documentation for specific battery information. The battery is marked with this symbol, which may include lettering to indicate cadmium (Cd), lead (Pb), or mercury (Hg). For proper recycling, return the battery to your supplier or to a designated collection point. For more information see: www.recyclethis.info.

According to the Batteries and Accumulators (Placing on the Market) Regulations 2008 and the Waste Batteries and Accumulators Regulations 2009: This product contains a battery that cannot be disposed of as unsorted municipal waste in the United Kingdom. See the product documentation for specific battery information. The battery is marked with this symbol, which may include lettering to indicate

cadmium (Cd), lead (Pb), or mercury (Hg). For proper recycling, return the battery to your supplier or to a designated collection point. For more information see: www.recyclethis.info.

Warning: This is a class A product. In a domestic environment this product may cause radio interference in which case the user may be required to take adequate measures.

#### **Industry Canada ICES-003 Compliance**

This device meets the CAN ICES-003 (A)/NMB-003(A) standards requirements.

This device complies with Industry Canada licence-exempt RSS standard(s). Operation is subject to the following two conditions:

- (1) this device may not cause interference, and
- (2) this device must accept any interference, including interference that may cause undesired operation of the device.

Le présent appareil est conforme aux CNR d'Industrie Canada applicables aux appareils radioexempts de licence. L'exploitation est autorisée aux deux conditions suivantes :

- (1) l'appareil ne doit pas produire de brouillage, et
- (2) l'utilisateur de l'appareil doit accepter tout brouillage radioélectrique subi, même si le brouillage est susceptible d'en compromettre le fonctionnement.

This equipment complies with IC RSS-102 radiation exposure limits set forth for an uncontrolled environment. This equipment should be installed and operated with minimum distance 20 cm between the radiator & your body.

ce matériel est conforme aux limites de dose d'exposition aux rayonnements, CNR-102 énoncée dans un autre environnement.cette eqipment devrait être installé et exploité avec distance minimale de 20 entre le radiateur et votre corps.

- (i) The device for operation in the band 5150-5250 MHz is only for indoor use to reduce the potential for harmful interference to co-channel mobile satellite systems;
- (ii) The maximum antenna gain permitted for devices in the bands 5250-5350 MHz and 5470-5725 MHz shall comply with the e.i.r.p. limit; and
- (iii) The maximum antenna gain permitted for devices in the band 5725-5825 MHz shall comply with the e.i.r.p. limits specified for point-to-point and non point-to-point operation as appropriate.
- (i)Les dispositifs fonctionnant dans la bande 5150-5250 MHz sont réservés uniquement pour une utilisation à l'intérieur afin de réduire les risques de brouillage préjudiciable aux systèmes de satellites mobiles utilisant les mêmes canaux.
- (ii) Le gain d'antenne maximal autorisé pour les appareils dans les bandes 5250-5350 MHz et 5470-5725 MHz doivent respecter le pire limiter; et
- (iii) Le gain d'antenne maximal autorisé pour les appareils dans la bande 5725-5825 MHz doivent respecter le pire limites spécifiées pour le point-à-point et l'exploitation non point à point, le cas échéant.



A급 기기: 이 기기는 업무용(A급) 전자파적합기기로써 판매자 또는 사용자는 이 점을 주의하시기바라며, 가정 외의 지역에서 사용하는 것을 목적으로 합니다.

# **Symbol Conventions**

The symbols that may be found in this document are defined as follows.

Symbol	Description	
<b>⚠</b> Danger	Indicates a hazardous situation which, if not avoided, will or could result in death or serious injury.	
Caution	Indicates a potentially hazardous situation which, if not avoided, could result in equipment damage, data loss, performance degradation, or unexpected results.	
iNote	Provides additional information to emphasize or supplement important points of the main text.	

# **Safety Instruction**

These instructions are intended to ensure that user can use the product correctly to avoid danger or property loss. Please read all the safety information carefully before using.

#### **Laws and Regulations**

Use of the product must be in strict compliance with the local electrical safety regulations.

#### **Transportation**

- Keep the device in original or similar packaging while transporting it.
- Keep all wrappers after unpacking them for future use. In case of any failure occurred, you need
  to return the device to the factory with the original wrapper. Transportation without the
  original wrapper may result in damage on the device and the company shall not take any
  responsibilities.
- DO NOT drop the product or subject it to physical shock. Keep the device away from magnetic interference.

#### **Power Supply**

- Please purchase the charger by yourself. Input voltage should meet the Limited Power Source (7.2 VDC, 890 mA) according to the IEC61010-1 standard. Please refer to technical specifications for detailed information.
- Make sure the plug is properly connected to the power socket.
- DO NOT connect multiple devices to one power adapter, to avoid over-heating or fire hazards caused by overload.

#### **Battery**

- Improper use or replacement of the battery may result in explosion hazard. Replace with the same or equivalent type only. Dispose of used batteries in conformance with the instructions provided by the battery manufacturer.
- The built-in battery cannot be dismantled. Please contact the manufacture for repair if necessary.
- For long-term storage of the battery, make sure it is fully charged every half year to ensure the battery quality. Otherwise, damage may occur.
- DO NOT charge other battery types with the supplied charger. Confirm there is no flammable material within 2 m of the charger during charging.
- DO NOT place the battery near heating or fire source. Avoid direct sunlight.
- DO NOT swallow the battery to avoid chemical burns.
- DO NOT place the battery in the reach of children.
- When the device is powered off and the RTC battery is full, the time settings can be kept for 3 months.
- The lithium battery voltage is 7.2 V, and the battery capacity is 4800 mAh.
- The battery is certified by UL2054.

#### Maintenance

- If the product does not work properly, please contact your dealer or the nearest service center.
   We shall not assume any responsibility for problems caused by unauthorized repair or maintenance.
- A few device components (e.g., electrolytic capacitor) require regular replacement. The average lifespan varies, so periodic checking is recommended. Contact your dealer for details.
- Wipe the device gently with a clean cloth and a small quantity of ethanol, if necessary.
- If the equipment is used in a manner not specified by the manufacturer, the protection provided by the device may be impaired.
- We recommend you send the device back for calibration once a year, and please contact the local dealer for the information on maintenance points.
- Please notice that the current limit of USB 3.0 PowerShare port may vary with the PC brand, which is likely to result in incompatibility issue. Therefore it's advised to use regular USB 3.0 or USB 2.0 port if the USB device fails to be recognized by PC via USB 3.0 PowerShare port.
- Your camera will periodically perform a self-calibration to optimize image quality and measurement accuracy. In this process the image will pause briefly and you'll hear a "click" as a shutter moves in front of the detector. The self-calibration will be more frequent during start up or in very cold or hot environments. This is a normal part of operation to ensure optimum performance for your camera.

#### **Using Environment**

- Make sure the running environment meets the requirement of the device. The operating temperature shall be -20°C to 50°C (-4°F to 122°F), and the operating humidity shall be 95% or less
- This device can only be safely used in the region below 2000 meters above the sea level.
- Place the device in a dry and well-ventilated environment.
- DO NOT expose the device to high electromagnetic radiation or dusty environments.
- DO NOT aim the lens at the sun or any other bright light.
- When any laser equipment is in use, make sure that the device lens is not exposed to the laser beam, or it may burn out.
- The device is suitable for indoor and outdoor uses, but do not expose it in wet conditions.
- The level of protection is IP 54.
- The pollution degree is 2.

#### **Technical Support**

The <u>https://www.hikmicrotech.com/en/contact-us.html</u> portal will help you as a HIKMICRO customer to get the most out of your HIKMICRO products. The portal gives you access to our support team, software and documentation, service contacts, etc.

#### **Emergency**

• If smoke, odor, or noise arises from the device, immediately turn off the power, unplug the power cable, and contact the service center.

#### **Laser Light Supplement Warning**



Warning: The laser radiation emitted from the device can cause eye injuries, burning of skin or inflammable substances. Prevent eyes from direct laser. Before enabling the Light Supplement function, make sure no human or inflammable substances are in front of the laser lens. The wave length is 650 nm, and the power is less than 1 Mw. The laser meets the IEC60825-1:2014 standard. Laser maintenance: It is not necessary to maintain the laser regularly. If the laser does not work, the laser assembly needs to be replaced in the factory under warranty. Keep the device power off when replacing laser assembly. Caution-Use of controls or adjustments or performance of procedures other than those specified herein may result in hazardous radiation exposure.

#### **Manufacture Address**

Room 313, Unit B, Building 2, 399 Danfeng Road, Xixing Subdistrict, Binjiang District, Hangzhou, Zhejiang 310052, China Hangzhou Microimage Software Co., Ltd.

COMPLIANCE NOTICE: The thermal series products might be subject to export controls in various countries or regions, including without limitation, the United States, European Union, United Kingdom and/or other member countries of the Wassenaar Arrangement. Please consult your professional legal or compliance expert or local government authorities for any necessary export license requirements if you intend to transfer, export, re-export the thermal series products between different countries.

# **Contents**

Chapter 1 Overview	1
1.1 Device Description	1
1.2 Main Function	1
1.3 Appearance	3
Chapter 2 Preparation	8
2.1 Charge Device	8
2.1.1 Charge Device via Cable Interface	8
2.1.2 Charge Battery via Charging Base	8
2.2 Mount Hand Strap	9
2.3 Change Interchangeable Lens	10
2.4 Tilt Lens and Screen	12
2.5 Power On/Off	13
2.5.1 Set Auto Power-off Duration	13
2.6 Sleep and Wake	13
2.7 Operation Method	14
2.8 Menu Description	15
Chapter 3 Display Settings	16
3.1 Focus	16
3.1.1 Focus Lens Manually	16
3.1.2 Laser Assisted Focus	17
3.1.3 Auto Focus	17
3.1.4 Continuous Autofocus	17
3.1.5 High Temperature Priority	18
3.2 Set Screen Brightness	18
3.3 Set Display Mode	18
3.4 Set Palettes	19
3.4.1 Set Alarm Mode Palettes	20
3.4.2 Set Focus Mode Palettes	20
3.5 Adjust Display Temperature Range	21

# Handheld Thermography Camera User Manual

3.6 Adjust Digital Zoom	22
3.7 Display OSD Info	22
Chapter 4 Temperature Measurement	23
4.1 Set Measurement Parameters	23
4.1.1 Set Unit	24
4.2 Set Image Measurement	24
4.3 Set Measurement Tool	25
4.3.1 Measure by Custom Spot	25
4.3.2 Measure by Line	26
4.3.3 Measure by Rectangle	27
4.3.4 Measure by Circle	28
4.4 Measure ΔT and ΔT Alarm	29
4.5 Temperature Alarm	30
4.5.1 Set Alarms for Exceptional Temperatures	30
4.6 Clear All Measurements	31
Chapter 5 Route Inspection	32
5.1 Create Inspection Route and Send Task to Device	32
5.2 Perform Route Inspection	33
5.3 Upload Inspection Result and View Report	35
Chapter 6 Picture and Video	37
6.1 Capture Picture	37
6.2 Record Video	39
6.3 View and Manage Local Files	40
6.3.1 Manage Albums	40
6.3.2 Manage Files	41
6.4 Local Analysis and Report Generation	43
6.5 Export Files	ΔΔ

# Handheld Thermography Camera User Manual

Chapter 7 Calculate Area Size	45
Chapter 8 Distance Detection	46
Chapter 9 Geographic Location Display	47
Chapter 10 Direction Display	48
10.1 Calibrate Compass	48
10.2 Magnetic Declination Correction	49
Chapter 11 Connect Bluetooth	50
Chapter 12 Set LED Light	51
Chapter 13 Cast Device Screen to PC	52
Chapter 14 Connect Device to Wi-Fi	53
Chapter 15 Set Device Hotspot	54
Chapter 16 Thermal View Mobile Client Connection	55
16.1 Connect via Wi-Fi	55
16.2 Connect via Hotspot	55
Chapter 17 HDMI Image Output	56
Chapter 18 Maintenance	57
18.1 View Device Information	57
18.2 Set Date and Time	57
18.3 Upgrade Device	57
18.4 Restore Device	58
18.5 Initialize Memory Card	58
18.6 About Calibration	58
Chapter 19 Appendix	59
19.1 Common Material Emissivity Reference	59
19.2 Device Command	59
19.3 Device Communication Matrix	60
19 <i>4</i> FAO	60

# **Chapter 1 Overview**

### 1.1 Device Description

The handheld thermography camera is a device with both optical images and thermal images. It can do thermography, distance measurement, video recording, snapshot capturing, alarm, and it can connect to Wi-Fi, hotspot and Bluetooth. The built-in high-sensitivity IR detector and high-performance sensor detects the variation of temperature and measure the real-time temperature. Refer to the production specification on HIKMICRO website for detailed information. The built-in laser module detects the target distance.

The device is easy to use, and adopts ergonomic design. It is widely applied to substations, electricity prevention detection of companies, and reconnaissance survey of construction field.

#### 1.2 Main Function

#### **Temperature Measurement**

Device detects the real-time temperature, and display it on the screen.

#### **Route Inspection**

Device can check the temperature of the check points in a predefined inspection route, and upload the results to center client for analysis.

#### **Distance Measurement**

Device can detect the target distance with the laser light.

#### **Fusion**

Device can display fusion of thermal view and optical view.

#### **Palette and Alarm**

Device supports multiple palettes, and you can set the palette mode according to the alarm function.

#### **Geographical Location and Direction Display**

For some models that are equipped satellite positioning module and compass, geographical location and direction display are supported.

Ţ <u>i</u> Note	
The function is supported by certain models of this series.	

#### **HDMI Output**

For some models that have a micro HDMI output interface, you can connect the device to a display unit to view live image.

#### **Client Software Connection**

 Mobile Phone: Use HIKMICRO Viewer to see live image, capture, and recording, etc. on your phone.



**HIKMICRO Viewer Android** 




**HIKMICRO Viewer iOS** 


PC: Use HIKMICRO Analyzer
 (https://www.hikmicrotech.com/en/industrial-products/hikmicro-analyzer-software.html) to see live image, capture, recording, and receive alarm message, etc. on your PC.
 Use HIKMICRO Inspector to create inspection routes, send route inspection task to devices, collect inspection results and generate analysis reports.


#### **Bluetooth**

Device can be connected to headset via Bluetooth, and you can hear the voice in the recording or capture.

# 1.3 Appearance










Figure 1-1 Appearance

Table 1-1 Button and Interface Description

No.	Description	Function
140.	Description	Menu Mode:
1	Navigation Button	
		• Press $\triangle \mathbf{\hat{q}}$ , $\nabla$ , $\Box$ , and $\Box$ to select parameters.
		Press OK to confirm.
		Non-Menu Mode:
		Press △Ŷ to turn on/off the LED light supplement.
		● Press and at to adjust focus.
2	File Button	Press to enter albums.
3	Back Button	Exit the menu or return to previous menu.
4 & 14	Function Button	Press to use the custom function.
5	Touch Screen	Show the live view interface.
5		● Touch-screen operation.
6	Focus Ring	Adjust focus to find clear targets.
7	Light Sensor	Sense the ambient brightness.
8	Microphone	Used to add voice note.
9	Zoom Button	Press $\mathbb T$ to zoom in, and press $\mathbb W$ to zoom out.
10	Diopter Adjustment Wheel	Adjust the dioptric correction for the viewfinder.
11	Carl or B. Harr	Press: capture snapshots/stop recording
11	Capture Button	Hold: start recording

# Handheld Thermography Camera User Manual

No.	Description	Function
12	Focus Button	Press to start focus.
12		Press: measure the distance with laser once
13	Laser Button	Hold: measure the distance with laser continuously
15	Hand Strap Attachment Point	Mount the hand strap.
16 & 34	Neck Strap Attachment Point	Mount the neck strap.
17	Tripod Mount	Mount the tripod.
18	Viewfinder	View live view through the viewfinder. See Display Switch Button.
10	Power Button	Press: standby mode/wake up device
19	Power Button	Hold: power on/off
20	Display Switch Button	Switch the LCD and the Viewfinder.
21	Eyepiece Plug	Protect the eyepiece.
22	Loudspeaker	Play voice note and voice alarm.
23	Optical Lens	View the optical image.
24	Laser Distance Meter	Measure the distance with laser.
25	Supplement Light	Increase ambient brightness in dark environment.
26	Thermal Lens	View the thermal image.
27	Memory Card Slot	Insert the memory card in it.
28	SIM Card Slot	Not Available.
29	Data Exchange Interface	Charge the device or export files with supplied cable.
	Indicator	Indicate the charging status of the device.
30		Solid red: charging normally
30		Flashing red: charging exception
		Solid green: fully charged
31	Micro HDMI Interface	Connect the device with HDMI cable. A cable converter (HDMI Type D to HDMI Type A) is included in the carrying case.
32	Battery Compartment	Install the battery in it.

# Handheld Thermography Camera User Manual

No.	Description	Function
33	Lens Release Button	Unlock the interchangeable lens.



The laser radiation emitted from the device can cause eye injuries, burning of skin or inflammable substances. Before enabling the light supplement function, make sure no human or inflammable substances are in front of the laser lens.

# **Chapter 2 Preparation**

# 2.1 Charge Device

### 2.1.1 Charge Device via Cable Interface

#### **Before You Start**

Please make sure the battery is installed before charging.

#### **Steps**

- 1. Lift the cover of cable interface.
- 2. Plug in the cable, and connect the power supply to charge the battery.




Figure 2-1 Charge Battery via Type-C Cable

## 2.1.2 Charge Battery via Charging Base

**i**Note

Please charge the battery with the cable and power adapter supplied by the manufacturer (or according to the input voltage from the specifications).

#### **Steps**

- 1. Put one or two batteries in the charging base.
- 2. Connect the supplied charging base to the power supply. The indicator in the middle is green if it works properly.

- 3. The left and right indicators show the charging status of the batteries.
  - Solid red: charging normally.
  - Solid green: fully charged.
- 4. Draw the battery from the charging base, and disconnect charging base from the power supply.




Figure 2-2 Charge Battery via Charging Base

# 2.2 Mount Hand Strap

#### Steps

1. Thread the hand strap through the hand strap clutch.



Figure 2-3 Thread Hand Strap

2. Insert one end of the hand strap through the two hand strap attachment points




Figure 2-4 Thread Hand Strap Through Attachment Points

3. Thread hand strap through the hand strap buckle, and fasten the hand strap.




Figure 2-5 Fasten Hand Strap

4. Adjust the tightness of the hand strap as needed.

# 2.3 Change Interchangeable Lens

An interchangeable lens is a thermal lens that can be mounted to the device for obtaining different FOVs, scene scopes, and temperature measurement ranges.

#### **Before You Start**

- Purchase a suitable interchange lens recommended by the device manufacturer.
- The device pops up a window to show the lens information or the calibration program when detecting a mounted lens.

#### Steps

1. Press the lens release button and turn the interchangeable lens anticlockwise until it stops.




Figure 2-6 Release Lens

2. Remove the interchangeable lens carefully.




Figure 2-7 Remove Lens

3. Align the two white index marks on the device and the lens.




Figure 2-8 Align White Marks

4. Push the lens into position.




Figure 2-9 Mount Lens

5. Rotate the lens clockwise to fix it. The lens makes a click when it locks in place.




Figure 2-10 Fix Lens

# **i**Note

- Dust on the detector may cause blemishes in the image. If you can find the dust on the detector, use pressurized air from a compressed air canister to blow it off; but If you cannot find the dust, we recommend you contact your dealer or the nearest service center for cleaning.
- A prompt pops up on the interface if the lens is not calibrated to the camera. Please contact
  the dealer or the nearest service center for lens calibration, or the temperature
  measurement accuracy is affected.

### 2.4 Tilt Lens and Screen

You can tilt the lens and screen for different observation angles, as shown in Figure 2-11.




Figure 2-11 Tilt Lens and Screen

# 2.5 Power On/Off

#### **Power On**

Remove the lens cover, and hold of for over three seconds to turn on the device. You can observe the target when the interface of the device is stable.



It may take at least 30 s until the device is ready for using when you power on it.

#### **Power Off**

When the device is turned on, hold of for three seconds to power off the device.

#### 2.5.1 Set Auto Power-off Duration

Select ♣, and go to **Device Settings** → **Auto Power-off** to set the automatic shutdown time for device as required.

# 2.6 Sleep and Wake

Sleep and wake function is used to save energy and increase battery time.

#### **Sleep and Wake Manually**

Press to enter sleep mode and press it again to wake the device up.

#### **Set Auto Sleep**

Select , and go to **Device Settings**  $\rightarrow$  **Auto Sleep** to set waiting time before auto sleep. When there is no button pressing or screen tapping operation on device for more than the set waiting time, device enters sleep mode automatically.

Press 🕛 to wake the device up.

#### **Device Sleep, Scheduled Capture and Video Recording**

When the device is recording a video clip or on scheduled capturing, auto sleep will not be triggered. However, press will stop the video recording or scheduled capture and force the device into sleep mode.

# 2.7 Operation Method

The device supports both touch-screen control and button control.

#### **Touch-Screen Control**

Tap the screen to set parameters and configurations.




Figure 2-12 Touch-screen Control

#### **Button Control**

Press the navigation buttons to set parameters and configurations.




Figure 2-13 Button Control

- In menu mode, press  $\triangle \mathbf{\hat{Y}}$ ,  $\nabla$ ,  $\square$ , and  $\square$  to select parameters.
- Press **OK** to confirm.

# 2.8 Menu Description

In the observation interface, tap the screen to show the menu bar, and swipe down to call the swipe-down menu.



Figure 2-14 Main Menu



Figure 2-15 Swipe-Down Menu

- (1) Shutter
- (2) Level & Span
- (3) Palettes
- 4 Temperature Measurement
- (5) Image Mode
- 6 Settings
- (7) Wi-Fi
- 8 Bluetooth
- (9) Hotspot
- (10) Screen Cast
- (11) Flashlight
- 12 Dark/Bright Mode
- (13) Compass
- (14) GPS
- (15) Inspection Mode

# **Chapter 3 Display Settings**



Your device will periodically perform a self-calibration to optimize image quality and measurement accuracy. In this process the image will pause briefly and you'll hear a "click" as a shutter moves in front of the detector. The self-calibration will be more frequent during start up or in very cold or hot environments. This is a normal part of operation to ensure optimum performance for your device.

#### 3.1 Focus

Adjust the lens focal length properly before you set any other configurations, or it may affect the image display and temperature accuracy.

### 3.1.1 Focus Lens Manually

#### **Steps**

- 1. Power on the device.
- 2. Aim the device lens to the appropriate scene.
- 3. Adjust the focus ring clockwise or anticlockwise until the target is clear. See Figure 3-1.





Figure 3-1 Focus Lens

 $\bigcap_{\mathbf{i}}$ Note

DO NOT touch the lens, or the imaging effect may be affected.

#### 3.1.2 Laser Assisted Focus





The laser radiation emitted from the device can cause eye injuries, burning of skin or inflammable substances. Prevent eyes from direct laser. Before enabling the function, make sure no human or inflammable substances are in front of the laser lens.

#### **Before You Start**

- It is recommended to use this function in a non-glare environment, such as indoor environment.
- The target should have good light reflection, such as white paper and cables.

#### Steps

- 1. Select  $\blacksquare$ , and go to **Device Settings**  $\rightarrow$  **Focus**  $\rightarrow$  **Focus Mode** to enable **Laser Assisted Focus**.
- 2. In the live view interface, aim image center at the target and press  $\bigcirc$  to finish focus.

Note

DO NOT adjust the focus ring in this mode, or it will interrupt the focus process.

#### 3.1.3 Auto Focus

The device focuses automatically by comparing the brightness, contrast, etc. in current scene. **Steps** 

- 1. Select  $\blacksquare$ , and go to **Device Settings**  $\rightarrow$  **Focus**  $\rightarrow$  **Focus Mode** to enable **Auto Focus**.
- 2. In the live view interface, aim the cursor at the target and press  $\bigcirc$  to finish focusing.

Note

DO NOT adjust the focus ring in this mode, or it will interrupt the focus process.

#### 3.1.4 Continuous Autofocus

In continuous autofocus mode, the device focuses on the target automatically to make the scene clear. Use this mode when the device is stationary.



Disable continuous autofocus mode when the device is moving, or it may affect the device function.

Select  $\blacksquare$ , and go to **Device Settings**  $\rightarrow$  **Focus**  $\rightarrow$  **Focus Mode** to enable **Continuous Autofocus**. Then aim the device at the target, and the device focuses automatically.

Note

Focus ring adjustment does not take effect in this mode.

### 3.1.5 High Temperature Priority

Enable the high temperature priority function if you want to focus on the high temperature object in the observation scene.

Select **∰**, and go to **Device Settings** → **Focus** to enable **High Temperature Priority**.



The high temperature priority function is only supported in auto focus mode and continuous autofocus mode.

### 3.2 Set Screen Brightness

The device supports auto or manual screen brightness adjustment.

**Table 3-1 Screen Brightness Adjustment** 

Method	Operation	
Manual	Select <b>™</b> , and go to <b>Settings</b> → <b>Device Settings</b> → <b>Screen Brightness</b> to adjust the screen brightness. Or tap 🌣, and drag it to adjust the screen brightness.	
Auto	Select █, and go to Settings → Device Settings → Screen Brightness to enable Auto.	
	Devices adjust the screen brightness automatically when the ambient brightness changes.	

# 3.3 Set Display Mode

You can set the thermal/optical view of the device. **Thermal**, **Fusion**, **PIP**, **Visual**, and **Blending** are selectable.


#### **Steps**

- 1. Select from the main menu.
- 2. Tap the icons to select a view mode.



In thermal mode, the device displays the thermal view.





The hot part in the image are colored, and the else is blue.

#### **Blue Red**

The hot part in the image is colored red, and the else is blue.

3. Press  $\bigcirc$  to exit the setting interface.

Note

You can also press  $\subseteq$ , and  $\supseteq$  to switch the palettes.

#### 3.4.1 Set Alarm Mode Palettes

Alarm mode palettes allows to mark the targets of certain temperature range with a different color from the rest.

#### Steps

- 1. Select from the main menu.
- 2. Tap the icons to select an alarm rule type.

**Table 3-2 Icon Description** 

Icon	Alarm Mode	Description
	Above Alarm	Set the alarm temperature, and the targets with the temperature higher than the set value are displayed in red.
	Below Alarm	Set the alarm temperature, and targets with the temperature lower than the set value are displayed in blue.
	Interval Alarm	Set the alarm temperature section (e.g., 90 °C to 150 °C), and targets with the temperature in the range are displayed in yellow.
Ω	Insulation Alarm	Set the alarm temperature section (e.g., 90 °C to 120 °C), targets with the temperature out of the section (e.g., 70 °C or 125 °C) are displayed in purple or blue.

- 3. Optional: Press  $\Delta \mathbf{\hat{Y}}$  and  $\nabla$  to select between upper limit and lower limit.
- 4. Press 
  ☐ and ☐ to adjust the rule temperature.
- 5. Press 📛 to exit.

#### 3.4.2 Set Focus Mode Palettes

Focus mode palettes allows to mark the targets of certain temperature range with fusion palettes

and the others with white hot palettes.

#### **Steps**

- 1. Select from the main menu.
- 2. Tap the icons to select an alarm rule type.

**Table 3-2 Icon Description** 

Icon	Palettes Mode	Description
<b></b>	Above Focus	Set the temperature threshold, and the targets with the temperature higher than the set value are displayed with fusion palettes.
<b>়</b>	Below Focus	Set the temperature threshold, and targets with the temperature lower than the set value are displayed with fusion palettes.
<b></b>	Interval Focus	Set the temperature range (e.g., 90 °C to 150 °C), and targets in the range are displayed with fusion palettes.

- 3. Optional: Press  $\Delta \mathbf{Q}$  and  $\nabla$  to select between upper limit and lower limit.
- 4. Press 

  and 

  and 

  to adjust the rule temperature.
- 5. Press 📛 to exit.

## 3.5 Adjust Display Temperature Range

Set a temperature range and the palette only works for targets within the temperature range. You can adjust the temperature range.

#### Steps

- 1. Select from the main menu.
- 2. Select auto adjustment III or manual adjustment ...

For Manual mode, you can go to Local Settings  $\rightarrow$  Measurement Settings  $\rightarrow$  Manual Level and Span Mode to choose a preferred mode. Level Only and Level & Span are selectable.

- Level Only: You can manually adjust the maximum temperature and the minimum temperature respectively to expand or reduce the temperature range.
- Level & Span: You can adjust the maximum temperature and the minimum temperature at the same time while remaining the same temperature range.

Auto Adjustment	The device adjusts temperature range parameters automatically.
Level Only	a. Tap on an interest area of the screen. A circle is displayed around the area, and the temperature range readjusts to show as many

	<ul> <li>details of the area as possible.</li> <li>b. Press and and not appear and on the value on screen to lock or unlock a value.</li> <li>c. Press A and √, or scroll the adjustment wheel on the screen to fine-tune the max. temperature and the min. temperature respectively.</li> <li>d. Tap OK to finish.</li> </ul>
Level & Span	<ul> <li>a. Tap on an interest area of the screen. A circle is displayed around the area, and the temperature range readjusts to show as many details of the area as possible.</li> <li>b. Press △♀ and ▽ to fine-tune the max. temperature and the min. temperature respectively.</li> <li>d. Tap OK to finish.</li> </ul>

# 3.6 Adjust Digital Zoom

In the live view interface, press  $\mathbb{T}$  and  $\mathbb{W}$  to zoom in or zoom out by 0.1× continuously. Hold  $\mathbb{T}$  and  $\mathbb{W}$  to zoom in or zoom out by 1×, 2×, etc.

# 3.7 Display OSD Info

Select , and go to **Display Settings** to enable the information on-screen display.

#### **Status Icon**

The device status icons, for example, battery status, memory card, hotspot, etc.

#### **Time and Date**

Device time and date.

#### **Parameters**

Thermography parameters, for example, target emissivity, temperature unit, etc.

#### Distance

Laser measurement result.

#### **Brand Logo**

The brand logo is a manufacturer logo displayed on the upper right corner of the screen.

# **Chapter 4 Temperature Measurement**

The temperature measurement function provides the real-time temperature of the scene and display it on the left of your screen. This function is turned on by default.



Your device will periodically perform a self-calibration to optimize image quality and measurement accuracy. In this process the image will pause briefly and you'll hear a "click" as a shutter moves in front of the detector. The self-calibration will be more frequent during start up or in very cold or hot environments. This is a normal part of operation to ensure optimum performance for your device.

#### 4.1 Set Measurement Parameters

You can set measurement parameters to improve the accuracy of temperature measurement.

#### **Steps**

- 1. Select , and go to Measurement Settings.
- 2. Set Temperature Range, Emissivity, etc.

#### **Temperature Range**

Select the temperature measurement range. The device can detect the temperature and switch temperature range automatically in **Auto Switch** mode.

#### **Emissivity**

Refer to **Common Material Emissivity Reference** to set the emissivity of your target.

#### **Reflection Temperature**

If any object (not the target) of high temperature is in the scene, and the target emissivity is low, set the reflection temperature as the high temperature to correct the temperature effect.

#### **Distance**

The distance between the target and the device. You can customize the target distance or select the target distance as **Near**, **Middle**, or **Far**.


#### **Humidity**

Set the relative humidity of current environment.

#### **External Optics Transmittance**

Set the optics transmittance of external optical material (e.g.: germanium window) to improve the temperature measuring accuracy.

#### **External Optics Temperature**



When you install a macro lens, the device switches to macro mode automatically. In macro mode, settings such as display mode, distance, and optical transmissivity cannot be modified.

3. Return to previous menu to save the settings.



Select  $\blacksquare$ , and go to **Device Settings**  $\rightarrow$  **Device Initialization**  $\rightarrow$  **Remove All Measurement Tools** to initialize the temperature measurement parameters.

#### 4.1.1 Set Unit

Select **⚠**, and go to **Device Settings** → **Unit** to set the temperature unit and distance unit.

# 4.2 Set Image Measurement

You can set four types of temperature measurement tools.

**Table 4-1 Icon Description** 

Icon	Description
<b></b>	Center Spot Temperature Measurement
-;-	Hot Spot Temperature Measurement
+	Cold Spot Temperature Measurement
	Custom Spot Temperature Measurement

The setting methods of center spot, hot spot, and cold spot temperature measurement are all the same. Here is the example of setting hot spot temperature measurement.

#### Example

Tap on the interface, the device locates the spot of the highest temperature, and displays Max.: XX.

## 4.3 Set Measurement Tool

You can set temperature measurement parameters to improve the accuracy of temperature measurement.

#### **Before You Start**

Set parameters such as **Humidity**, **External Optics Transmittance** and **Reflection Temperature**. For detailed explanations, see **Set Measurement Parameters**.

#### Steps

- 1. Tap 💠 to call the measurement tool bar.
- 3. Select a type of temperature measurement tool.

**Custom Spot** For configuring custom spot tools, see *Measure by Custom Spot*.

**Line** For the configuring line tools, see *Measure by Line*.

**Rectangle** For the configuring rectangle tools, see <u>Measure by Rectangle</u>.

**Circle** For the configuring circle tools, see *Measure by Circle*.

ΔT For the configuring ΔT tools, see **Measure ΔT and ΔT Alarm**.



**Figure 4-1 Temperature Measurement Tools** 

#### What to do next

Set temperature alarm, then alarm actions such as audible warning and flashing alarm will be triggered when the tested temperature exceeds the set alarm value. See <u>Temperature Alarm</u>.

## 4.3.1 Measure by Custom Spot

The device can detect the temperature of a custom spot.

#### Steps


- 1. Tap 🖶 to add a default spot.
- 3. Move the spot with the navigation buttons, or tap on the touch-screen to select a spot and move it.
- 4. Tap 🔳 to modify temperature measurement parameters.

#### **Emissivity**

Refer to **Common Material Emissivity Reference** to set the emissivity of your target.

#### **Distance**

Set the distance between the target and the device.



– Tap the end of the line, and press  $\subseteq$ ,  $\supseteq$ ,  $\triangle ?$  and  $\nabla$  to extend or shorten the line.

- Tap and drag the end of the line to extend or shorten it.

3. Adjust the length of the line.

4. Tap **a** to modify temperature measurement parameters.

#### **Emissivity**

Refer to **19.1 Common Material Emissivity Reference** to set the emissivity of your target.

#### **Distance**

Set the distance between the target and the device.

#### Max./Min./Average Temperature

Tap to enable the temperature types to display. The max. temperature, min. temperature, and average temperature of the line can be displayed on the left of the screen.

5. Press 📛.



If the tool-specific emissivity and distance are set, the measurement is conducted based on the parameters. Otherwise, the parameters set from **Measurement Settings** are used for measurements.

6. Modify the set line tool, hide or display the tool and measurement results, etc.

0

Tap to enter the editing interface and modify temperature measurement parameters such as emissivity and distance.

**@**/@

Tap to hide or display the tool and measurement results.

亩

Tap to delete the tool.

7. Press  $\bigcirc$  to save and exit.

## 4.3.3 Measure by Rectangle

#### **Steps**

- 1. Tap to generate a default rectangle.
- 2. Move the rectangle to the required position.
  - Tap the rectangle, and press  $\subseteq$ ,  $\stackrel{\cdot}{\sqsubseteq}$ ,  $\triangle ?$  and  $\nabla$  to move the rectangle up/down/left/right.
  - Tap and drag the rectangle on touch-screen to move it to the required position.
- 3. Adjust the size of the rectangle.
  - Tap one corner of the rectangle, and press  $\Box$ ,  $\Box$ ,  $\triangle$  and  $\nabla$  to enlarge or contract the rectangle.
  - Tap and drag the corner of the rectangle on touch-screen to enlarge or contract it.
- 4. Tap **a** to modify temperature measurement parameters.

#### **Emissivity**

Refer to **Common Material Emissivity Reference** to set the emissivity of your target.

#### **Distance**



#### Max./Min./Average Temperature

Tap to enable the temperature types to display. The max. temperature, min. temperature, and average temperature of the rectangle area can be displayed on the left of the screen.

6. Press  $\bigcirc$  to save the settings.



If the tool-specific emissivity and distance are set, the measurement is conducted based on the parameters. Otherwise, the parameters set from **Measurement Settings** are used for measurements.

7. Repeat the above steps to set other rectangle tools.

Note

At most five rectangle tools are supported.

8. Optional: Modify the rectangle tools, hide or display the tools and measurement results, etc.

0

Tap to enter the editing interface and modify temperature measurement parameters such as emissivity and distance.

**@**/@

Tap to hide or display the tool and measurement results.

命

Tap to delete the tool.

9. Press  $\bigcirc$  to save and exit.

## 4.3.4 Measure by Circle

#### **Steps**

- 1. Tap to generate a default circle.
- 2. Move the circle to the required position.
  - Tap the circle, and press  $\leq$ ,  $\geq$ ,  $\Delta$  and  $\nabla$  to move the circle up/down/left/right.
  - Tap and drag the circle on touch-screen to move it to the required position.
- 4. Adjust the size of the circle.
  - Tap one point on the circle, and press  $\subseteq$ ,  $\supseteq$ ,  $\triangle$ ? and  $\nabla$  to enlarge or contract the circle.
  - Tap and drag one point of the circle on touch-screen to enlarge or contract it.
- 5. Tap 🔳 to modify temperature measurement parameters.

#### **Emissivity**

Refer to **Common Material Emissivity Reference** to set the emissivity of your target.

#### Distance

Set the distance between the target and the device.

#### Max./Min./Average Temperature

Tap to enable the temperature types to display. The max. temperature, min. temperature, and average temperature of the circle area can be displayed on the left of the screen.

6. Press  $\Longrightarrow$  to save the settings.



If the tool-specific emissivity and distance are set, the measurement is conducted based on the parameters. Otherwise, the parameters set from **Measurement Settings** are used for measurements.

7. Repeat the above steps to set other rectangle tools.



At most five circle tools are supported.

8. Optional: Modify the circle tools, hide or display the tools and measurement results, etc.

0

Tap to enter the editing interface and modify temperature measurement parameters such as emissivity and distance.

**@**/@

Tap to hide or display the tool and measurement results.

俞

Tap to delete the tool.

9. Press  $\bigcirc$  to save and exit.

## 4.4 Measure ΔT and ΔT Alarm

By comparing the temperature difference ( $\Delta T$ ) between measurement tools, or between a measurement tool and a certain temperature, device can recognize temperature exception more accurately and rapidly. This function is commonly applied to the temperature measurement of temperature-sensitive targets such as current transformers.

#### **Before You Start**

Configure at least one temperature measurement tool.

- For configuring custom spot tools, see *Measure by Custom Spot*.
- For the configuring line tools, see *Measure by Line*.
- For the configuring rectangle tools, see <u>Measure by Rectangle</u>.
- For the configuring circle tools, see *Measure by Circle*.

#### **Steps**

- Tap △.
- 2. Add a ΔT tool.

- 1) Input a tool name for the ΔT tool in Name of Tool.
- 2) Select Compared Object.



You can compare the temperature difference between different or the same measurement tools, between a measurement tool and a number, etc. If you select **Number** as a compared object, input the value manually.

#### 3) Set Alarming ΔT.

When the detected  $\Delta T$  is greater than the set alarming  $\Delta T$ , device triggers alarms.

- 4) Tap **OK** to save the settings.
- 3. Optional: Repeat above steps to set other  $\Delta T$  tools.
- 4. Optional: Modify the ΔT tools, hide or display the tools and measurement results, etc.

Tap to enter the editing interface and modify  $\Delta T$  tool parameters such as emissivity and distance.

Tap to hide or display the ΔT tool and measurement results.

 $oxed{m}$  Tap to delete the  $\Delta T$  tool.

- 5. Press 🗂 to save and exit.
- 6. Enable ΔT Alarm.
  - 1) Select  $\square$ , and go to Measurement Settings  $\rightarrow$  Alarm Settings.
  - 2) Tap to enable ΔT Alarm.

Note

If you do not enable  $\Delta T$  Alarm, the alarm linkages also take effect, but the  $\Delta T$  alarm information will not be uploaded to the surveillance center.

## 4.5 Temperature Alarm

When the temperature of targets triggers the set alarm, the device will perform configured actions, such as, flashing the rule frame, making an audible warning, or sending notification to the client software.

# **4.5.1 Set Alarms for Exceptional Temperatures**

Alarm actions such as audible warning and flashing alarm are triggered when the tested temperature exceeds the set alarm value.

#### **Steps**

1. Select  $\blacksquare$ , and go to Measurement Settings  $\rightarrow$  Alarm Settings.

- 2. Tap to enable **Temperature Alarm**.
- 3. Set the alarm parameters.

#### **Alarm Threshold**

When the tested temperature exceeds the threshold, the device sends alarm notification to the client software. It beeps if the audible warning is enabled. The rectangle flashes red if the rectangle tool is configured.

#### **Alarm Linkage**

- Audible Warning: The device beeps when target temperature exceeds the alarm threshold.
- Flashing Alarm: The flash light flashes when target temperature exceeds the alarm threshold.



If you set rectangle and circle tools to measure temperature, the alarm threshold and linkage method settings only works in the measured areas. Otherwise, the parameters are valid for pixel-to-pixel temperature measurement (whole-screen temperature measurement).

## 4.6 Clear All Measurements

Tap 🥻 to clear all set temperature measurement tools.

# **Chapter 5 Route Inspection**

In certain situations that require temperature check for many inspect points, you can use the client software to create inspection routes that cover all the points and send a route inspection task to the device. After the device examines the temperatures of the inspect points, it uploads the results to the client software.




Figure 5-1 Route Inspection Work Flow

The device receives the tasks from and uploads the inspection results to the PC client software by its WLAN or Hotspot function.

## 5.1 Create Inspection Route and Send Task to Device

Create the inspection routes on the HIKMICRO Inspector. The client should be connected to the device before sending the route inspection task.

#### **Before You Start**

- Download the HIKMICRO Inspector from <a href="http://www.hikmicrotech.com">http://www.hikmicrotech.com</a> and install the program to your PC.
- The PC should support WLAN function.

#### **Steps**

- 1. Open HIKMICRO Inspector.
- 2. Create inspect points and routes. See the user manual of HIKMICRO Inspector for instructions.
- 3. Connect your device and PC to the same LAN. Available methods as below:
  - Connect your PC and your device to the same Wi-Fi network. For device Wi-Fi connection, go to Settings → Connections → WLAN to select and connect desired Wi-Fi network. See
     Connect Device to Wi-Fi for more instructions.
  - Connect your PC to the device hotspot. Turn on and set up device hotspot by Settings →
     Connections → Hotspot. See <u>Chapter 15 Set Device Hotspot</u> for more instructions.
- 4. Click **Device Management** to add your device into the client. See the user manual of HIKMICRO Inspector for instructions.
- 5. Go to **Task Management**  $\rightarrow$  **Route Management** to select a route and click **Apply to Device**.

#### What to do next

Check your device to see if the task is successfully received.

## **5.2 Perform Route Inspection**

After receiving inspection tasks from the PC client, you can hold the device and check the inspect points on the route. Upload the results when the inspection is finished.

#### **Before You Start**

- Make sure your device has a memory card installed. See *Appearance* for instructions.
- Connect the device to the PC client, and make sure that your device has received inspection tasks from the PC client. See the user manual of HIKMICRO Inspector for instructions.

#### **Steps**

1. Enter inspection mode to start.

Enter the mode by one of the following ways:

- Tap 2 in the swipe-down menu to enter the inspection route mode.
- Go to Settings → Device Settings → Inspection Route Mode to enable the function.



When in the inspection route mode, the device file are not accessible.

- 2. Select an inspection route task.
  - 1) Press to call the menu of inspection route mode.
  - 2) Select to show currently received inspection route tasks.
  - 3) Select a task to start.
- 3. Press  $\triangle \mathbf{\hat{Y}}$  and  $\nabla$  to see the inspect points that need to be checked in this task and go to the inspect points one by one.
- 4. Check the temperature of an inspect point and mark the result. Operations are different according to the check-in type and diagnosis type settings of each inspect point.

Check-In Type and	Operation		
Diagnosis Type			

# Check-in Required and Manual Diagnosis

- 1. In the live view interface, press to switch to the optical channel.
- 2. Aim the scanning frame to the QR code. The device will scan the QR code, and prompt the scanning result.
- 3. Press again to capture and mark the inspect point images according to the reference images until all required parts and angles of the point are captured.
- 4. After capturing the last required image, mark the diagnosis

result. You can select **Normal, Emergency Defect, Severe Defect, General Defect,** or **Pending** from

# Check-in Required and Auto Diagnosis

- 1. In the live view interface, press to switch to the optical channel.
- 2. Aim the scanning frame to the QR code. The device will scan the QR code, and prompt the scanning result.
- 3. Press again, then the device captures inspect point images according to the reference images until all required parts and angles of the point are captured.
- 4. After capturing the last required image, device automatically marks the inspect point images.

# Check-in Not Required and Manual Diagnosis

- 1. Aim the device to the inspect point.
- 2. Press to capture the inspect point images according to the reference images.
- 3. After capturing the last required image, mark the diagnosis result. You can select **Normal**, **Emergency Defect**, **Severe Defect**, **General Defect**, or **Pending** from

# Check-in Not Required and Auto Diagnosis

- Aim the device to the target and press , then device captures inspect point images one by one according to the reference images until all required parts and angles of the point are captured.
- 2. After capturing the last required image, device automatically marks the inspect point images.
- 5. After completing the current inspect point check, the device moves on to the next point automatically. Repeat the step to check other points.
- 6. Press to see the captured image of every inspect point. Change the status if necessary.

#### What to do next

- You can delete inspection tasks by selecting a task and tapping 🛅.
- Upload the results to the PC client after finishing the route inspection. See the user manual of HIKMICRO Inspector for instructions.

## 5.3 Upload Inspection Result and View Report

Upload the inspection results to the client software for central management and report generation.

#### **Before You Start**

Connect your device with the PC that has the client software installed. See the step of device connection in <u>5.1 Create Inspection Route and Send Task to Device</u> for instructions.

#### **Steps**

- 1. Open HIKMICRO Inspector.
- 2. Click and Task Management and check desired tasks.
- 3. Click **Read Inspection Result** to download the results from the device.



Figure 5-2 Task Management

The task status is shown in **Completion**.

4. Click on a finished task name to show result details.




Figure 5-3 Inspection Results

5. Optional: Check a task or the desired inspect points and click **Report** for further analysis and report generation in HIKMICRO Analyzer.



- HIKMICRO Analyzer should be installed in your PC. Download the program from <a href="https://www.hikmicrotech.com/">https://www.hikmicrotech.com/</a>.
- ullet For the operations instructions in HIKMICRO Analyzer, read the user manual from **Help** o

#### **User Manual**.

• Please keep HIKMICRO Analyzer up-to-date for the best compatibility and user experience.




Figure 5-5 Analysis in HIKMICRO Analyzer

# **Chapter 6 Picture and Video**

Insert memory card into the device, then you can record videos, capture snapshots, and mark and save important data.



- Device does not support capturing or recording when the menu is shown.
- When the device is connected to your PC, it does not support capturing or recording.
- Go to Settings → Capture Settings → Filename Header, you can set the filename header for capturing or recording to distinguish the files recorded in a specify scene.
- Go to Settings → Device Settings → Device Initialization to initialize the memory card as needed.

## **6.1 Capture Picture**

#### **Before You Start**

- Install a memory card for image storage.
- Press  $\triangle \mathbf{\hat{Y}}$  in live view interface to enable flashlight in dark environment.

#### **Steps**

- 1. Select **4.**, and go to **Capture Settings** to set the capturing parameters.
  - 1) Set **Capture Mode**. Three modes are available.

#### **Capture One Image**

Press once to capture one image.

$\sim$	$\sim$			
1	•			
1	1	N.	_	te
۱ ۵	_	IV	О	ıe

If you need to edit captured images immediately, enable Edit before Saving.

#### **Continuous Capture**

Set the continuous capture amount after select this mode.

Press in live view, and device captures the set amount of images continuously.


#### **Scheduled Capture**

Set the interval for scheduled capture after select this mode.

Press in live view, and the device captures images according to the set interval. Press again or press to stop capturing.

2) Set the naming rule for the saved files. The default image naming is filename header + saving time. **Filename Header** is configurable. Saving time is the device system time when the saving occurs.

3) Optional: If a visual image is needed to be saved separately, enable Save Visual Image and



- 4) Optional: If the thermal images are exported and viewed on a high resolution screen, enable **SuperIR** before capturing. Resolution of captured images with **SuperIR** is 4 times as the original ones.
- 2. Press to exit. In the live view interface, aim the lens to your target and press to capture images.



- For Capture One Image, if Edit before Saving is NOT enabled, the live image freezes and is saved in the default saving album. If Edit before Saving is enabled, the device enters the image editing interface.
- For **Continuous Capture/Scheduled Capture**, a counter displays in top of the screen showing the completed amounts of capturing.
- 3. Edit the image.



Select text note and enter the editing page. Tap on screen to input content and Press OK to save.



Select voice note and enter the voice recording page. Press  $\mathbb{O}\mathbb{K}$  to start recording and release the button to stop recording.



Select QR code and the device enters the scanning mode. Aim the scanning frame at a QR code. Device reads the code and save the code information.



After all information added to the image, select **Save** to exit.

#### What to do next

- Press to enter albums to view and manage files and albums. See *Manage Albums* and *Manage Files* for operation instructions.
- You can connect your device to PC to export local files in albums for further use. See <u>Export</u> <u>Files</u>.

## 6.2 Record Video



- Install a memory card for video storage.
- Press  $\triangle \mathbf{\hat{Y}}$  in live view interface to enable the flashlight in dark environment.

#### **Steps**

1. Select  $\square$ , and go to Capture Settings  $\rightarrow$  Video Type to set the video format.

#### **Radiometric Video**

Raw thermal data is attached in videos of this format. They can only be played and further analyzed with HIKMICRO Analyzer.



- The frame rate of this format is 5 fps.
- A video clip should be no longer than 10 minutes, and its size should be no larger than 4
   GB.
- When the storage space is smaller than 500 MB, radiometric video recording is not allowed. Accidentally stopped recordings are not saved.


#### MP4

Recorded videos are saved in .mp4 format. These video clips can be played on local device, and any players that support this format (HIKMICRO Analyzer does not support playing this video format.).

2. In the live view interface, hold to start recording. The recording icon and count down number display in the interface.

The recording signs for radiometric video and MP4 videos are different. When you see 00:00:28, it is recording a MP4 video. When you see radiometric video.

3. When you finish, hold again to stop recording. The recording video will be saved automatically and exit.



#### What to do next

Check the saved videos from in menu mode. See <u>View and Manage Local Files</u> for more information.

# 6.3 View and Manage Local Files

Device captured images and videos are saved in local albums. You can create, delete, rename and set an album as the default saving album. For files, operations, such as browsing, moving and deleting, are available.

#### Steps

- 1. Press to enter **Albums**.
- 2. To create, rename, delete and set an album as the default saving album, see *Manage Albums* for instructions.
- 3. For file operations, such as, moving or deleting a file, see *Manage Files* for instructions.
- 4. Press 🛨 to exit.

**Table 6-1 File Type and Description** 

File Type	Description	
MP4 videos, format .mp4	Videos of this format can be played on local device, or exported to play by any other supported player.	
-	But, this format cannot be played by HIKMICRO Analyzer	
Radiometric images, format .jpeg	Images can be viewed on local device, or exported and analyzed in HIKMICRO Analyzer.	

## 6.3.1 Manage Albums

You can create several albums to manage captured images and video files on your device. Newly captured images and videos are saved in the **Default Saving Album**.

Task	Operations
	<ol> <li>Press to enter Albums.</li> <li>Tap to add a new album.</li> </ol>
	3. A soft keyboard is displayed, where you can enter the name of the album by touching the screen.
	4. Tap 🔽 to finish.
Create a New Album	
	Note
	The newly created album becomes the default saving album and appears at the top of the album list.
Rename an Album	1. Press to enter Albums.
Nelianie an Album	2. Select the album to rename.

Task	Operations
	<ul> <li>3. Tap ***, and select Rename. A soft keyboard is displayed.</li> <li>4. Tap to delete the old name, and enter the new name for the album by touching the screen.</li> <li>5. Tap to finish.</li> </ul>
Change the Default Saving	<ol> <li>Press to enter Albums.</li> <li>Select the album you want to use as the default saving album.</li> <li>Tap ***, and select Set as Default Saving Album.</li> </ol>
Album	The default saving album appears at the top of the album list.
Delete an Album	<ol> <li>Press to enter Albums.</li> <li>Select the album you want to delete.</li> <li>Tap ***, and select Delete. A prompt box appears on the interface.</li> <li>Tap OK to delete the album.</li> </ol>
Delete an Album	The files in an album are deleted as well when deleting the album. Move the files to other albums if they are still needed. See <u>Manage Files</u> for instructions.

# **6.3.2** Manage Files

You can delete the recorded files and move the files to other albums on the device.

Task	Operations
Delete a File	<ol> <li>Press to enter Albums.</li> <li>Tap to select the album storing the file to be deleted.</li> <li>In the album, tap to select the file to be deleted.</li> <li>Tap ***, and select Delete. A prompt box appears on the interface.</li> <li>Tap OK to delete the file.</li> </ol>
Delete Multiple Files	1. Press to enter <b>Albums</b> .

Task	Operations
	<ol> <li>Tap to select the album storing the files to be deleted.</li> <li>In the album, tap , and tap the files to be deleted.</li> <li>Tap . A prompt box appears on the interface.</li> <li>Tap OK to delete the files.</li> </ol>
	You can also delete a single file in this way.
Move a File	<ol> <li>Press to enter Albums.</li> <li>Tap to select the album storing the file to be moved.</li> <li>In the album, tap to select the file to be moved.</li> <li>Tap ••• , and select Move. The album list is displayed.</li> <li>Tap to select the album to move to.</li> </ol>
Move Multiple Files	<ol> <li>Press to enter Albums.</li> <li>Tap to select the album storing the files to be moved.</li> <li>In the album, tap to select the files to be moved.</li> <li>Tap to select the album list is displayed.</li> <li>Tap to select the album to move to.</li> </ol> Note You can also move a single file in this way.
Add Text Note on File	<ol> <li>Press to enter Albums.</li> <li>Tap to select the album storing the file to be edited.</li> <li>In the album, tap to select the file to be edited.</li> <li>Tap ***, and select Text Note. A soft keyboard is displayed.</li> <li>Enter the text note by touching the screen.</li> <li>Tap to finish.</li> <li>What to do next</li> <li>You can open the edited photo to view the text note.</li> </ol>
Add Voice Note on File	<ol> <li>Press to enter Albums.</li> <li>Tap to select the album storing the file to be edited.</li> <li>In the album, tap to select the file to be edited.</li> <li>Tap ***, and select Voice Note. A microphone is displayed.</li> <li>Tap the microphone to start/stop recording.</li> </ol>

Task	Operations
	What to do next You can open the edited photo, and tap the recording.
	Note Voice note can only be added on images.

1 1	•			
1 1		No	_ •	_
1 _	_=	N	ЭΤ	ρ
	$\overline{}$		•	•

Tap ✓ to select all files, and tap ☐ to cancel the selection.

## 6.4 Local Analysis and Report Generation

For captured local radiometric images, you can modify temperature measurement rules on the device. At the same time, the device supports temperature measurement result analysis, and you can generate a report.

#### **Steps**

- 1. Select and open an image in the album.
- 2. Tap the image to show editing options, and tap 🚺 to enter the editing interface.
- 3. (Optional) Tap the rules of the image to modify the temperature measurement rule. See <u>Set</u> <u>Measurement Tool</u> for reference. Tap the screen again to finish.
- 4. (Optional) Tap , then a dialogue box pops up. You can save, cancel, or exit the current operation.
- 5. Tap **a** to enter the report generation interface.
- 6. Enter the **Title** and **Author** for the report. Tap **v** to generate the report.

#### What to do next

Refer to **Export Files** to export the PDF report for local analysis.

$\sim$	$\sim$	i
	•	
1		Note
1 _		ivote

You can analyze the radiometric image again on HIKMICRO Analyzer.

## **6.5 Export Files**

Connect the device to your PC with supplied cable, you can export the recorded videos, captured snapshots, and PDF reports.

**i**Note

Cast screen should be turned off before exporting files, or the PC cannot detect the disk. Go to **Settings**  $\rightarrow$  **Connections**  $\rightarrow$  **USB Cast Screen** to check the function status.

#### **Steps**

- 1. Open the cover of cable interface.
- 2. Connect the device to your PC with cable and open the detected disk.
- 3. Select and copy the videos or snapshots to PC to view the files.
- 4. Disconnect the device from your PC.

**i**Note

For the first time connection, the driver will be installed automatically.

#### What to do next

You can import the captured snapshots to HIKMICRO Analyzer for further data analysis. See the User Manual of HIKMICRO Analyzer (embedded in the client software,  $Help \rightarrow User Manual$ ) for the operation guide.

# **Chapter 7 Calculate Area Size**

The device can calculate the size of rectangles and show results on screen.

#### **Steps**

- 1. Select  $\square$ , and go to Measurement Settings  $\rightarrow$  Area Size Calculation.
- 2. Enable Area Size Calculation.
- 3. Draw one or several rectangles on screen.

The rectangles are those you draw for temperature measurement. See <u>Measure by Rectangle</u> for instructions.

4. In the live view interface, aim a rectangle at the target and press the laser button.



Make sure the lens is parallel to the target when measuring the area size.

#### Result

The target size is displayed above the rectangle.

# **Chapter 8 Distance Detection**

The laser range finder consists of a laser transmitter and a laser receiver. The device detects the distance to a target by measuring the time it takes for a laser pulse to reach the target and return to the laser receiver. This time is converted to a distance, which is displayed on the screen.

#### **Before You Start**

- It is recommended to use this function in non-glare environment, such as indoor environment.
- It is recommended that the target has good light reflection, such as white paper and cable.

#### Steps

- 1. Select  $\square$ , and go to **Device Settings**  $\rightarrow$  **Display Settings**.
- 2. Enable **Distance**.
- 3. Press to save and exit.
- 4. In the live view interface, aim the cursor at the target and hold the laser button.
- 5. Release the lase button to finish distance measurement.

#### Result

The distance displays on the screen when distance measurement is finished.

# **Chapter 9 Geographic Location Display**

Equipped with satellite positioning modules, the device is able to display its longitude and latitude on the live image and in the captured images.

#### **Steps**

- 1. Select  $\square$ , and go to **Device Settings**  $\rightarrow$  **GPS**.
- 2. Tap to enable the GPS function. The device will prompt the GPS positioning result.

#### Result

You can see the location displayed at lower right corner of the screen.

## Note

- The satellite module is not able to receive signals when the device is indoor. Place the device in an empty outdoor space to receive signals.
- In an outdoor space, wait for a moment for the device to display its location.
- The location information is also attached in captured radiometric images. You can read the location by HIKMICRO Analyzer.
- Location display is only supported by models with satellite positioning modules.

# **Chapter 10 Direction Display**

Equipped with a compass, the device is able to display its direction on the live image and in the captured images.

Note

The function is supported by certain models.

Select , and go to Device Settings > Compass to enable the compass modules, then follow the pop-up instructions to calibrate the compass. See Calibrate Compass for more information.

After successful calibration, you can see the direction displayed at lower right corner of the screen. It is recommended to read the direction when you lay the device horizontally.

To increase the direction accuracy, you can set the magnetic declination correction. See Magnetic Declination Correction for instructions.

The direction information is also attached in captured radiometric images. You can read the

# 10.1 Calibrate Compass


direction by HIKMICRO Analyzer.

Compass calibration is a must for correction direction display.

You need to calibrate the compass when you enable the function for the first time.

#### **Steps**

- 1. Call the calibration guide by the following ways.
  - When you enable compass for the first time, or the compass is magnetically interfered, compass calibration guide pops up.
  - Select Manage and go to Device Settings → Compass to turn the function off and on again.
  - Tap  $\square$  in the swipe-down menu to quickly turn on/off the compass.
- 2. Follow the screen instructions to move and rotate the device.



Note

During calibration, keep moving and rotating the device to make sure that the device faces

every possible directions.

- Calibration Level indicates the validity of calibration, higher level means more accurate compass reading. Calibration succeeds when the status bar in the live view interface shows, and Calibrated Level turns to 3.
- 3. Stop moving the device when calibration success message pops up.

#### Result

Compass status turns to **Calibrated** on the settings page.

## **10.2 Magnetic Declination Correction**

Magnetic declination is the angle variation between magnetic north and true north. Adding the magnetic declination to the compass increase the accuracy of direction reading. Go to Local Settings  $\rightarrow$  Device Settings  $\rightarrow$  Compass  $\rightarrow$  Magnetic Declination Correction to add the declination of device location.

# **Chapter 11 Connect Bluetooth**

You can record and hear the sound contained in the videos or images via bluetooth headsets after pairing the device with bluetooth headsets successfully.

# Select ♣, and go to Connections → Bluetooth. Tap to enable the bluetooth. Note You can also press or OK to quit pairing.

The device will search the nearby enabled bluetooth headsets and pair them automatically.

#### Result

After pairing you can record and hear the sound via the headsets while recording and playing the video or image.

# **Chapter 12 Set LED Light**

In live view mode, press  $\triangle \mathbf{Q}$  to enable/disable the LED light. Or tap  $\blacksquare$  on the swipe-down menu.

# **Chapter 13 Cast Device Screen to PC**

The device supports casting screen to PC by UVC protocol-based client software or player. You can connect the device to your PC via a type-C cable, and cast the real-time live view of the device to your PC.

#### **Steps**

- 1. Select , and go to Connections → USB Cast Screen to turn on the function on device. Or tap in the swipe-down menu to turn on/off USB Cast Screen.
- 2. Open the UVC protocol-based client software on your PC.
- 3. Use a type-C cable to connect your device with PC.

#### What to do next

For more instructions about how to cast the screen, please visit our website: *https://www.hikmicrotech.com*.

# **Chapter 14 Connect Device to Wi-Fi**

#### **Steps**

- 1. Select  $\square$ , and go to **Connections**  $\rightarrow$  **WLAN**.
- 2. Tap to enable Wi-Fi, and the searched Wi-Fi will be listed.




Figure 14-1 Wi-Fi List

- 3. Select Wi-Fi to connect to and a soft keyboard is displayed.
- 4. Enter the password.
- 5. Tap to hide the keypad and connect Wi-Fi.



- DO NOT tap **space**, or the password may be incorrect.
- Leaving the Wi-Fi setting interface does not interrupt the connection.

#### Result

A Wi-Fi icon shows on the main interface when the connection is completed.

# **Chapter 15 Set Device Hotspot**

With the device hotspot, other equipment with Wi-Fi function can join the device for data transmission.

#### Steps

- 1. Select  $\mathbb{Z}$ , and go to **Connections**  $\rightarrow$  **Hotspot**.
- 2. Tap to enable hotspot function.
- 3. Tap **Set Hotspot**. A soft keyboard is displayed.



Figure 15-1 Set Hot Spot

4. Set the password for the hotspot by touch the screen.



- When setting the password, do not tap **space**, or the password may be incorrect.
- The password should be at least 8 digits, consisting of numbers and characters.
- 5. Tap to save.

# **Chapter 16 Thermal View Mobile Client Connection**

The device supports both Wi-Fi connection and hotspot. Connect the device to HIKMICRO Viewer, and you can control the device via mobile client.

#### 16.1 Connect via Wi-Fi

#### **Before You Start**

Download and install HIKMICRO Viewer on your phone.

#### **Steps**

- 1. Connect your device to a Wi-Fi network. See *Connect Device to Wi-Fi* for instructions.
- 2. Connect your phone to the Wi-Fi network that the device is in.
- 3. Launch the app and follow the startup wizard to create, and register an account.
- 4. Search and add the device to the mobile client.

#### Result

You can view the live view, capture snapshots, and record videos via the client.

## 16.2 Connect via Hotspot

#### **Before You Start**

Download and install HIKMICRO Viewer on your phone.

#### Stens

- Turn on the device hop spot and complete hot spot settings. See <u>Set Device Hotspot</u> for instructions.
- 2. Connect your phone to the Hot Spot of the device.
- 3. Launch the app and follow the startup wizard to create, and register an account.
- 4. Search and add the device to the mobile client.

#### Result

You can view the live view, capture snapshots, and record videos via the client.

# **Chapter 17 HDMI Image Output**

You can view the image on the display unit for details with this function. If your device has a micro HDMI output interface, connect the device and a display unit to cast the image.
Note
This function is only supported by the models with micro HDMI output interface.

# **Chapter 18 Maintenance**

## **18.1 View Device Information**

Select  $\square$ , and go to **Local Settings**  $\rightarrow$  **Device Settings**  $\rightarrow$  **Device Information** to view the device information.

#### 18.2 Set Date and Time

#### **Steps**

- 1. Select  $\square$ , and go to Local Settings  $\rightarrow$  Device Settings  $\rightarrow$  Time and Date.
- 2. Set the date and time.
- 3. Press to save and exit.



Go to **Display Settings** to enable or disable time and date display.

# 18.3 Upgrade Device

#### **Before You Start**

Please download the upgrade file from the official website <a href="http://www.hikmicrotech.com">http://www.hikmicrotech.com</a> or contact the custom service and technical support to get the upgrade file first.

#### **Steps**

- 1. Connect the device to your PC with cable and open the detected disk.
- 2. Copy the upgrade file and paste it to the root directory of the device.
- 3. Disconnect the device from your PC.
- 4. Reboot the device and then it will upgrade automatically. The upgrading process will be displayed in the main interface.



After upgrading, the device reboots automatically. You can view the current version in **Device Settings**  $\rightarrow$  **Device Information**.

#### **18.4 Restore Device**

Select  $\blacksquare$ , and go to **Device Settings**  $\rightarrow$  **Device Initialization**  $\rightarrow$  **Restore Device** to initialize the device and restore default settings.

## 18.5 Initialize Memory Card

When a memory card is use on the handheld thermal camera for the first time, it needs to be initialized first.

Select ♣, and go to **Device Settings** → **Device Initialization** → **Format Storage Card** to initialize the memory card.



If there are files in the memory card, make sure that the files has been backed up before memory card initialization. Once the card is initialized, data and files cannot be recovered.

## 18.6 About Calibration

We recommend you send the device back for calibration once a year, and please contact the local dealer for the information on maintenance points. For more detailed calibration services, please refer to <a href="https://www.hikmicrotech.com/en/calibrationservices/2">https://www.hikmicrotech.com/en/calibrationservices/2</a>.

# **Chapter 19 Appendix**

# 19.1 Common Material Emissivity Reference

Material	Emissivity
Human Skin	0.98
Printed Circuit Board	0.91
Concrete	0.95
Ceramic	0.92
Rubber	0.95
Paint	0.93
Wood	0.85
Pitch	0.96
Brick	0.95
Sand	0.90
Soil	0.92
Cloth	0.98
Hard Paperboard	0.90
White Paper	0.90
Water	0.96

## 19.2 Device Command

Scan the following QR code to get device common serial port commands. Note that the command list contains the commonly used serial port commands for HIKMICRO thermal cameras.



## 19.3 Device Communication Matrix

Scan the following QR code to get device communication matrix.

Note that the matrix contains all communication ports of HIKMICRO thermal cameras.



# 19.4 FAQ

Scan the following QR code to get device common FAQ.





Facebook: HIKMICRO Thermography

Instagram: hikmicro\_thermography E-mail: support@hikmicrotech.com

LinkedIn: HIKMICRO

YouTube: HIKMICRO Thermography Website: https://www.hikmicrotech.com